


Message




From: Cook, David [DAVID.COOK@Illinois.gov]
Sent: 6/20/2019 1:53:58 PM
To: Bosscher, Valerie [bosscher.valerie@epa.gov]; Cobb, Rick [rick.cobb@illinois.gov]; Deltoral, Miguel [deltoral.miguel@epa.gov]; Girard, Alexander [girard.alexander@epa.gov]; Holst, Linda [holst.linda@epa.gov]; Lippert, Allison [lippert.allison@epa.gov]; Lytle, Darren [Lytle.Darren@epa.gov]; Pierard, Kevin [pierard.kevin@epa.gov]; Porter, Andrea [porter.andrea@epa.gov]; Poy, Thomas [poy.thomas@epa.gov]; Mary Reed [mary.f.reed@illinois.gov]; Schock, Michael [Schock.Michael@epa.gov]; Sofat, Sanjay [Sanjay.Sofat@Illinois.gov]; Tanaka, Joan [Tanaka.Joan@epa.gov]; Vance, Steve [STEVE.VANCE@Illinois.gov]
Subject: FW: WQ data (University Park)
Attachments: ATT00001.txt; WDS Sampling - WQP 06192019 1651 hrs.xlsx; [External] RE: WQ data; HACH - Phosphate Orthophosphate) Instruction.pdf

From: Cook, David
Sent: Thursday, June 20, 2019 8:53 AM
To: Biggs, Kim <Kim.Biggs@Illinois.gov>; Cobb, Rick <RICK.COBB@Illinois.gov>; Kim, John J. <John.J.Kim@Illinois.gov>; Nallatan, Segundo <SEGUNDO.NALLATAN@Illinois.gov>; Olson, Joanne <Joanne.Olson@Illinois.gov>; Reed, Mary F <MARY.F.REED@Illinois.gov>; Rettig, Todd <Todd.Rettig@illinois.gov>; Roche, Laura <Laura.Roche@Illinois.Gov>; Sofat, Sanjay <Sanjay.Sofat@Illinois.gov>; Vance, Steve <STEVE.VANCE@Illinois.gov>
Subject: FW: WQ data

From: Crockett, Christopher S <CSCrockett@aquaamerica.com>
Sent: Thursday, June 20, 2019 8:50 AM
To: Cook, David <DAVID.COOK@Illinois.gov>; Sofat, Sanjay <Sanjay.Sofat@Illinois.gov>
Subject: [External] RE: WQ data

This is the WQP data



Christopher S. Crockett, Ph.D., P.E.
Vice President/Chief Environmental Officer
Aqua America
762 W. Lancaster Ave., Bryn Mawr, PA 19010
O: 610.645.4207 M: 215.850.5304
  

From: Cook, David <DAVID.COOK@Illinois.gov>
Sent: Thursday, June 20, 2019 9:06 AM
To: Crockett, Christopher S <CSCrockett@aquaamerica.com>; Sofat, Sanjay <Sanjay.Sofat@Illinois.gov>
Subject: RE: WQ data

Chris, please resend the spreadsheet and instrument instructions. Thanks.

From: Crockett, Christopher S <CSCrockett@aquaamerica.com>
Sent: Wednesday, June 19, 2019 5:47 PM
To: Cook, David <DAVID.COOK@Illinois.gov>; Sofat, Sanjay <Sanjay.Sofat@Illinois.gov>
Subject: [External] WQ data

Dear David and Sanjay,

Please see the attached WQP data update for today.

As you can see in the data the ortho as P levels are now nearly 1 mg/L in the distribution system.

Water Distribution samples for phosphate were measured using:

Hach Kit, Phosphorus, Reactive (Orthophosphate) Method 8048 (Phos Ver3 and AccuVac Ampuls)

Instructions attached

Please let me know if you have any questions.



Christopher S. Crockett, Ph.D., P.E.
Vice President/Chief Environmental Officer
Aqua America

762 W. Lancaster Ave., Bryn Mawr, PA 19010
O: 610.645.4207 M:215.850.5304



From: Crockett, Christopher S
Sent: Wednesday, June 19, 2019 6:37 PM
To: Cook, David <DAVID.COOK@Illinois.gov>; sanjay.sofat@illinois.gov
Subject: RE: Flyer to residents

Dear David and Sanjay,

Attached is a copy of the map delineating the general areas for the DO NOT CONSUME (YELLOW) and lifted areas of the UP system based on building age, plumbing, and sampling.



Christopher S. Crockett, Ph.D., P.E.
Vice President/Chief Environmental Officer
Aqua America

762 W. Lancaster Ave., Bryn Mawr, PA 19010
O: 610.645.4207 M:215.850.5304



State of Illinois - CONFIDENTIALITY NOTICE: The information contained in this communication is confidential, may be attorney-client privileged or attorney work product, may constitute inside information or internal deliberative staff communication, and is intended only for the use of the addressee. Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify the sender immediately by return e-mail and destroy this communication and all copies thereof, including all attachments. Receipt by an unintended recipient does not waive attorney-client privilege, attorney work product privilege, or any other exemption from disclosure.